

APPLICATION No.: 16023

TAP CLEARED

LOCATION: 124 Frederick St

OWNER:

31-313

MEASURES: E from Cleveland St 48.9'
N from S Line Frederick St 8.5'
E from W Line House 3.2'

1" COPPER SERVICE

8-21-2019: Lead service line replacement program

Phase 1, TYPE CU, Diameter 1 inch, Water Pressure 100

Distance from main to curb stop 10'

Distance curb stop to meter 16.2'

Distance from curb face to curb stop 3.0'

Depth of service 4.8'

Total length of new pipe installed 16.2'

Curb stop replaced: NO Size 3/4"

Corporation replaced: NO Size 3/4"

Ball Valve furnished: YES Size 1"

Remarks: 1- 3/4" union installed where shown

DATE

BEF.

AFT.

REMARKS

12/4/87:reamed

[illegible][illegible]

CHARGE OUTS

