

APPLICATION No.: 16027

LOCATION: 402 - 404 Park St

OWNER: Curtis Perry

31-313

MEASURES: 3/4" Copper 11/18/1914

New Measures: 6-19-08

N from N line	Sycamore St	92.0
W from E line	Park St	5.9
N from S line	House	19.0
S from N line	House	5.4
W from W line	House	21.0
Main to property line		18.0
Pipe inside property		17.0

6/19/08 - Nelson Cardoso renewed service from property line into cellar. Owner charged \$100 (\$70.00 inspection fee & \$30 Turn-on fee) Inspected by: Percy Reynolds

-----

TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]

APPLICATION No.: 16027

LOCATION: 402-404 Park

OWNER: H. Lindsey

MEASURES: 5/8"

N from

W from E line

S from N line

Sycamore

park

House

92.0 ft.

9.0 ft.

5.4 ft.

Jan. 8, 1973 Renewed from  $\frac{1}{2}$  ft. outside curb stop to  
6 ft. inside curb stop.  
6 $\frac{1}{2}$  ft. - 3/4" Copper tubing 3/4" Hays curb stop  
2 wipe joints - - -

1-16-01 Zenone Const. renewed from main to property line.  
Stock: 25 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,  
1 - Caldwell Stop Box, 1 - 5/8"x3/4" lead to cop. adapt.XS,  
1 - 5/8"x3/4" Fig.413, Zenone Const. to maintain cut.

2/6/04 Lk still in street, & 2 pinholes @ lead ball. No damage at this time. See screen 15 for more info.

2/13/04 Renewed from 1/2 ft. outside curb stop to property line.  
Stock: 8 ft. 3/4" copper tubing; Caldwell stop box;  
5/8" x 3/4" lead-cop adapt. XXS

See screen 15

## TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

1-16-01 Tap reamed

2-17-04

115

2004-070-3238

[illegible]

## CHARGE OUTS