

APPLICATION No.: 16037

TAP CLEARED

8804-0037 ✓LOCATION: 527 SawyerOWNER: Hormedias PatnaudeMEASURES: 3/4"

W from	Summer	75.0 ft.
S from N line	Sawyer	9.3 ft.
E from W line	House	14.0 ft.

1/25/88 Renewed from 1' outside curb stop to a point 5ft
6ft-3/4" copper tubing, 1-3/4" curb stop, 1-Caldwell stop box
2-5/8x3/4 lead to cop adapt xxs

6/23/89: Renewed from main to a point 1.0 f.t

Stock: 1.0 ft. 3/4" copper tubing 1-3/4x3/4 Fig. 413

===== 1 - 5/8" x 3/4" lead to cop adapt. XXS

8-30-2000 Renewed from main to property line. Stock:

33 ft. - 3/4" Copper tubing, 1 - 3/4" Curb stop,

1 Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop.

adapt. XXS.

Tilcon to maintain cut.

June 2003 Renewed from new 8" main to a point 2 ft.

Stock: 2 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop
cplg., comp; 3/4" corporation tap

DATE

BEF.

AFT.

REMARKS

6/22
8925-39106/23/89: TAP REAMED8-30-2000 Tap reamed

all at 100 ft. elevation

7/19/89

[illegible]

CHARGE OUTS

[illegible]