

APPLICATION No.: 16073

TAP CLEARED

LOCATION: 209 Princeton

OWNER: Arthur C. Beanier

CHECK CHECK.

MEASURES: 5/8"

| | | |
|---------------|--------------|-----------|
| W from | Ashley Blvd. | 187.3 ft. |
| S from N line | Princeton | 9.3 ft. |
| E from W line | House | 15.3 ft. |

November 18, 1963 Renewed from 7 ft. outside curb stop to 10 ft. outside curb stop.

3 ft. 3/4" copper tubing 1 3/4" copper coupling A-1525
2 lbs wiping solder

August 30, 1963 Renewed from 6" outside curb stop to 4 ft. inside curb stop.

4 1/2 ft. 3/4" copper tubing 1 3/4" cop. to cop. stop
2 lbs. wiping solder

December 10, 1948 Leak at tap. No pipe used.

August 30, 1948 Leak on joint, street side of curb stop. No pipe.

12/6/91: Renewed from main to prop line

Stock: 34ft 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xs

1- 3/4x5/8 Fig.413

=====

DATE

BEF.

AFT.

REMARKS

12/6 9149 3520

12/6/91: TAP REAMED

[illegible]

CHARGE OUTS

[illegible]