

APPLICATION No.: 16135

TAP CLEARED ✓

LOCATION: 20 MerrillOWNER: James GoggeshallMEASURES: 5/8"

S from

W from E line

N from S line

Bates

Merrill

House

105.0 ft.

7.0 ft.

2.5 ft.

11-20-98 Renewed from main to property line. Stock:
25 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,
1 - Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop.
adapt. XXS, 1 - 5/8" x 3/4" Fig. 413.

3-5-02 Renewed from 4' inside curb stop to ins. cellar.
(16ft. ins. prop. line) Stock: 20ft.- 3/4" Copper tubing,
1- 3/4" x 3/4" cop to cop cplg., comp. R. Canesa Const. to maintain cut.

2/8/07 Repaired service broken by Gas Co. between main and curb
stop. Stock; 2 ft. 3/4" copper tubing; 2 - 3/4" cop-cop cplgs.
J Velez

- - - - -

DATE

BEF.

AFT.

REMARKS

11-20-98

Tap reamed

984705208

[illegible]