

APPLICATION No.: 16163

TAP CLEARED

LOCATION: 89 PrincetonOWNER: Jos. DextrageMEASURES: 5/8"

W from	Concord	103.6 ft.
S from N line	Princeton	9.1 ft.
W from E line	House	13.5 ft.

 February 5, 1968 Renewed from $\frac{1}{2}$ ft. outside curb stop to a point
 2 ft. inside curb stop.
 2 $\frac{1}{2}$ ft. of $\frac{3}{4}$ " copper tubing used. Total- 2 wiped joints
 1 $\frac{3}{4}$ " Mueller curb stop.

4-2-01 Renewed from main to property line. Stock:
 28 ft. - $\frac{3}{4}$ " Copper tubing, 1 - $\frac{3}{4}$ " Curb Stop,
 1 - Caldwell Stop Box, 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " lead to cop. adapt.
 XS, 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413.

3/23/01 Owner Frank Lima requested renewal - 10 ft. punch.

5/24/01 Gave owner deadline of 5/31/01 to renew. He is not want service renewed. Rec'd results of
 lead sample (6) & does not feel he needs to renew service.

DATE

BEF.

AFT.

REMARKS

3/23/01

4:30
pm

2001-120-3431

4-2-01 Tap reamed

[illegible]

CHARGE OUTS

[illegible]