

16170



244 Eugenia

J. C. De Mello Jr.

5/8"

Ashley Blvd.

287.8

Eugenia

8.2

House

7.2

000 001 0-1 0-2 0-3

December 2, 1975 Renewed from 6" outside the curb
stop to inside of the cellar wall. Leak at curb stop.
24 ft. 3/4" copper tubing (13 ft. inside)
1 3/4" curb stop 1 Caldewll stop box
1 5/8" x 3/4" lead to copper adapter XXS

10/21/04 Renewed from main to curb stop. Stock: 10 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" Fig. 413

Tap reamed

METER HISTORY

[illegible]

CHARGE OUTS