

APPLICATION No.: 16230

TAP CLEARED 85-15 0632

LOCATION: 613 Summer

OWNER: J Adamouicz

MEASURES:  $3/4''$

N from

N from

E from W line

S from N line

Coggeshall

Summer

House

78.8 ft.

6.5 ft.

9.1 ft.

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

4/10/85	TAP REAMED
---------	------------

8-16-04	64E V. CC	7:30	2004-340.0477
---------	--------------	------	---------------

8/16/04	Tap reamed
---------	------------

January 18, 1962 Renewed from  $\frac{1}{2}$  ft. outside curb stop to 3 ft. inside the curb stop.

3½ ft. of ¾" copper tubing

1 3/4" cop. to cop. stop

2 lbs. wiping solder

4/10/85: Renewed from main to a point 6½ft. outside of  
main Stock: 6.5ft. ¾" copper tubing 1 3/4x5/8 lead  
to cop adapt. xxs 1 3/4x3/4 Fig.413

== == == ==

== == == == ==

3/16/04 Renewed from main to property line. Stock: 18 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" lead-cop adapt. XXS; 3/4" x 3/4" Fig. 413 Tap reamed

7/20/06 Renewed from property line to to inside cellar. (16 ft. inside property line) Stock: 16 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop cplg., comp

6/26/15 tap leak st 2' cop main exposed renewed lead  
from main to c/s stock 11'; 3/4" cop tubing, 1 3/4 c/s, 1

$$\frac{5}{8} \times \frac{3}{4}$$

[illegible]

## CHARGE OUTS

[illegible]