

APPLICATION No.: 16237

## TAP CLEARED

LOCATION: 84 Irvington Cor. Concord

OWNER: Mary Jane Turness

MEASURES: S from <sup>5/8"</sup> Irnington 12.6 ft.  
E from W line Concord 6.5 ft.  
S from N line house 2.9 ft.

July 25, 1997: REnewed from main to a point 1ft outside of tap  
Stock: 1ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xxs  
1ft outside of tap 1-3/4x5/8 Fig 413

=====

2/17/04 Renewed from 1/2 ft. outside curb stop to property  
line. Stock: 8 ft. 3/4" copper tubing; 3/4" curb stop;  
Caldwell stop box; 2 - 5/8" x 3/4" lead-cop adapt. XXS

-----

DATE

BEF.

AFT.

REMARKS

7/25/97

973007226

7/25/97: tap reamed

2/17/04 830 am 2004-0600-514

[illegible]

## CHARGE OUTS

[illegible]