

APPLICATION No.: 16242

## TAP CLEARED

LOCATION: 352 Bonney St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES: New measures for 3/4" curb stop

S from S line Jouvette St	83.5
W from E line Bonney St	7.9
N from N line House	0.4
N from S line House	25.0

11/23/09 - City crew killed this service at the tap  
on the main & relocated this service off Bonney St  
(see new measures)

10 ft - 3/4" copper tubing; 1 - 3/4" curb stop;

1 Caldwell stop box; 1- 3/4" x 3/4" cop to cop cplg, comp

1 - 3/4" Corp Tap. Foreman: Frank Bento

-----

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.: 16242

TAP CLEARED 8822 2826

LOCATION: 352 Bonney St.

OWNER: Mrs. Carrie Pacheco

MEASURES: 5/8" H lead June 11, 1915

E from Bonney St. 7.9 ft.

N from S lline Jouvette St. 8.5 ft.

E from W line bldg. 7.1 ft.

6/2/88: Renewed from 1/2' outside curb stop to a point 3 1/2 ft.

Stock: 3 1/2 ft. 3/4" copper tubing 1-3/4" curb stop

1 - Caldwell stop box 2-3/4x5/8 lead to cop adapt. xxs.

Aug 27, 1995:

Contractor was digging for foundation for church north of  
352 Bonney St. Installed lead-cop adaptor at S.L.Jouvette  
E.L.Bonney Copper runs south on Bonney in sidewalk to feed  
352 Bonney.

Stock:

4ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt. xxs

1- 3/4 x 3/4 cop-cop cplg.comp.

=====

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]



\* 352 APPLICATION No.: 16242

TAP CLEARED

LOCATION: ~~126 Jouvette~~ Cor. Bonney

OWNER: \_\_\_\_\_

MEASURES:

5/8"

E from

N from S line

E from W line

B onney

Jouvette

bldg.

7.9 ft.

8.5 ft.

7.1 ft.

DATE

BEF.

AFT.

REMARKS



[illegible]

## CHARGE OUTS

[illegible]