

APPLICATION No.: 16243

LOCATION: 246 mount pleasant st

OWNER:

31-313

MEASURES: 3/4 copper 12/27/17

S x SL sawyer st 111.9 ft

W x EL mt pleasant st	3.7 ft
-----------------------	--------

S x NL house	11.5 ft
--------------	---------

N x SL house	18 ft
--------------	-------

W x WL house	15 ft
--------------	-------

main to prop line	18 ft
-------------------	-------

pipe inside prop	12 ft
------------------	-------

renewal c/s to meter - contractor Cardoso

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 16243

TAP CLEARED



LOCATION: 246-48 Mt. Pleasant

OWNER: Vera Kozikowski

MEASURES: 3/4"

S from

Sawyer

111.9 ft.

W from E line

Mt. Pleasant

3.7 ~~6.4~~ ft.

S from N line

House

11.5 ft.

Jan. 13, 1954 Renewed from main to a point 1 1/2 ft. from main.

1 1/2 ft. - 3/4" Copper tubing 1 wipe joint

1" x 3/4" cop to i.f. cplg.

- - -

Jan. 2, 1963 Renewed from 1/2 ft. outside curb stop to 5 ft. inside curb stop.

5 1/2 ft. - 3/4" Copper tubing 3/4" cop to cop stop

2# wiping solder

- - -

AUG 20 1981

Renewed service from the main to the property line.

17.ft. 3/4" copper; 3/4" curb stop; stop box; 1-1" x 3/4"

Fig. 413; Note: No saddle used on transite pipe.

12/28/06 Service tapped on top of main.

M Rose, III

- - - - -

DATE

BEF.

AFT.

REMARKS

1/13/54

Reamed

AUG 20 1981

Reamed

[illegible]

CHARGE OUTS

[illegible]