

APPLICATION No.: 16244

TAP CLEARED

LOCATION: 252-4 Mt. Pleasant

OWNER: Wanda Dabrowski

DATE

BEF.

AFT.

REMARKS

AUG 20 1981

Reamed

MEASURES: 3/4"

S from

Sawyer

71.6 ft.

W from E line

Mt. Pleasant

4.0

~~6.8~~ ft.

S from N line

House

13.2 ft.

July 13, 1970 Renewed 1/2 ft. outside curb stop to inside cellar.

23 ft. - 3/4" Copper tubing      3/4" Curb stop  
1 wipe joint

- - -

AUG 20 1981

Renewed service from the main to the property line.

17.0ft. - 3/4" copper

1- 3/4" curb stop 1- Caldwell stop box

1- Fig. 413 1" x 3/4" Tap reamed

1- 5/8" x 3/4" lead-cop. adapt. XXS

Note: No saddle used on transite pipe.

[illegible]

## CHARGE OUTS

[illegible]