

APPLICATION No.: 16255

TAP CLEARED

LOCATION: 70 Hawthorn Cor. Cottage

OWNER: Harry Weiner

**MEASURES:**

 $\frac{3}{4}''$ 

W from Cottage

N from S line Hawthorn

E from W line house

46.3 ft.

6.8 ft.

14.9 ft.

APR 20 1983 -Renewed from 6" outside curbstop to 1.0 ft.  
inside of line. 6.5 ft.-3/4" copper; 3/4" curb stop; stop  
box; 2- 3/4" x 3/4" lead-cop. adapt. XS;

March 24, 1986 Repairs made to inside of cellar per E Rodriques who claims this must be done because it was leaking after a meter was installed.

1 - 3/4" IPS ball valve w/drain

1 - 5/8" x 3/4" lead to copper adapt XXS

1.2 ft. - 3/4" copper tubing

1 - 3/4" x 3/4" male to female adapt.

5-29-01 Renewed from main to curb stop. Stock:  
8ft-3/4" Copper tubing, 1-3/4" Curb Stop, 1-Caldwell Stop  
Box, 1-3/4"x3/4" Fig. 413.

[illegible]

## CHARGE OUTS

[illegible]