

APPLICATION No.: 16336

TAP CLEARED

LOCATION: 16 Landry st

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES: 3/4"

renewed main to prop line

1 ft 3/4" ball valve

25 ft 3/4" copper tubing

2 ft 3/4" 90* copper elbow

1 ft cast iron curb stop boxes

lead worker: ronald aguiar dpi

16 Landry

Date: 1/20/2017

Contractor: City of New Bedford

Renewed Main to Meter

Type of Pipe: Copper

Size: 3/4"

B Valve- 3/ 3/4" Ball Valve 4 Units 1 UOM Each

Cop- 3/4 Box of 3/4" Copper Tubbing Units 25 UOM Feet

Elbow- 3/4 3/4" 90* Copper Elbow Units 1 UOM Each

CiCrbBx Cast Iron Curb Stop Boxes Units 1 UOM Each

METER HISTORY

[illegible]

CHARGE OUTS

APPLICATION No.: 16336

TAP CLEARED



LOCATION: 16 Landry

OWNER: John Wilcoodk

DATE

BEF.

AFT.

REMARKS

10/16/67

Reamed

MEASURES:

N from

Brooklawn Driveway

145.5 ft.

W from E line

Landry

8.3 ft.

S from N line

House

8.2 ft.

9/4/57

Reamed

Oct. 16, 1967 Tap Reamed

Sept. 4, 1957 Repaired leak at tap.
1# wiping solder

NOTE: Corporation is 3 ft. S x curb stop

March 17, 1976 Renewed from main to a point 3 ft. from
main.

3 ft. - 3/4" Copper tubing 3/4" Corporation

5/8" x 3/4" lead connector

August 20, 1986

Repaired leak broken by Gas Co. by installing a
3/4" curb stop buried located:

W x E line Landry St .

19.6 ft.

E x main

10.3 ft.

Stock:-

5.6 ft. - 3/4" copper tubing

1 - 3/4" curb stop

2 - 5/8" x 3/4" lead to cop adapt XXS

Over gas main.

METER HISTORY

[illegible]

CHARGE OUTS