

471
469-471

APPLICATION No.: 16387

LOCATION: 469 Sawyer

OWNER: Jos Pietras

MEASURES: 3/4"

E from Myrtle 69.0 ft.

S from N line Sawyer 8.5 ft.

E from W line store 2.8 ft.

March 31, 1976 Renewed from 6" outside curb stop to 3 ft. inside curb stop. 3 1/2 ft. - 3/4" copper tubing 2 wipe joint 3/4" curb stop

4-20-2000 Renewed from main to inside cellar. (2 ft. ins. prop. line) Stock: 29 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box, 1 - 3/4" x 3/4" Fig. 413.

8-23-2000 Dug the street up found that the 413 was leaking. I tightened the 413, and it stopped leaking. There is copper from main to prop. line.

6/2/03 Renewed from the new 8" main to a point 2 ft. Stock: 2 ft. 3/4" copper tubing; 3/4" corp tap; 3/4" x 3/4" cop to cop cplg., comp. Inspected by: D Grenon

TAP CLEARED

DATE BEF. AFT. REMARKS

3/31/76 Reamed

9:00 4/24/00 2000 170 6419

Tap reamed 4-20-2000

[illegible]

CHARGE OUTS

[illegible]