



APPLICATION No.:

BEF.

AFT.

REMARKS

02/19/1981	Reamed Tap
------------	------------

31-313

S from Nash Rd 78.0 ft
W from E Line Church St 8.0 ft
S from N Line House 3.0 ft

1" Copper Service

05/08/2018 Lead Service Line Replacement Program

Phase 1 Contractor P. Gioioso and Son

Type CU, Diameter (in) 1, Water Pressure 69

Distance from main to curb stop (ft) 24.0

Distance curb stop to meter (ft) 20.5

Distance from curb face to curb stop (ft) 2.0

Depth of service (ft) 3.5

Total length of new pipe installed (ft) 47.5

Curb stop replaced: Yes, Size 1"

Corporation replaced: Yes, Size 1"

Ball Valve replaced: Yes, Size 1"

Remark: 24.0 Corp to CS, 19.5 CS to Hse, 1.0 Hse to Meter

3.0 WHIP total 47.5 1" copper installed

