

APPLICATION No.: 16395

TAP CLEARED

LOCATION:

24 Weaver St

OWNER:

31-313

MEASURES:

3/4 Copper

03.11.2020 - curbstop to meter replacement
roto rooter inspected by percy reynolds

EXE Line Field St 182.0

NXS Line Weaver St 6.5

WXE Line House 5.0

NXN Line House 13.8

Main to property line 18'

Pipe inside property 10'

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

APPLICATION No.: 16395

TAP CLEARED

LOCATION: 24 Weaver

OWNER: Antônio S. Simmons

MEASURES:

5/8"

E from Field 182.0 ft.
N from S Weaver 6.5 ft.
W from E house 5.0 ft.

Jan. 3, 1980: Renewed from 6" outside curb stop to property line.

5.8 ft.-3/4" copper

1-3/4" curb stop 1-Caldwell stop box

2-5/8" x 3/4" lead-cop. adapt. XS

JUL 30 1982 --Due to installation of 6" main, renewed from
main to 2 ft. front of main. 2.0 ft.-3/4"

copper; 5/8" x 3/4" lead-cop. adapt. XXS; 3/4" corporation
tap.

Sept. 1, 2007: Ch. 90 Proj. Renewed from main to prop. line.

10 ft. - 3/4" copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell Stop

Box, 1 - 3/4" Fig. 413, tap reamed.

DATE BEF. AFT. REMARKS

9/1/07

tap reamed

[illegible]