

APPLICATION No.: 16400

TAP CLEARED

LOCATION: 152 Front

OWNER:

MEASURES:

6"

Chapman gate-1 gate box

N from N line Elm 14.0

W from E line Front 5.6

N from S line Warehouse 88.5

Dec. 28, 1949 2 - 6" Clow sleeves

Location: 7 ft. W x Gate valve

14 ft. W x Gate Valve

- - -

Jan. 6 & 7, 1950 Removed 2 - 6" Clow sleeves &
replaced with 2 - 6" Dresser cplg.
6 ft. - 6" C.I. Warr. spun cement lined pipe

- - -

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

APPLICATION No.: 16400

TAP CLEARED

LOCATION: 152 Front

OWNER:

MEASURES:

6" on Firre Supply

2" trident 1483391

Shut off removed 8-29-67 T4
94

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]