

APPLICATION No.: 16412

TAP CLEARED

84-38-1291

87333211✓

LOCATION: 49 Stephen

OWNER: Manl Costa

DATE

BEF.

AFT.

REMARKS

8/14/87: TAP REAMED

MEASURES: 5/8"

S from	Mathew	189.0 ft.
E from W line	Stephen	8.0 ft.
S from N line	House	12.2 ft.

Sept. 19, 1984:

Renewed from 1/2' outside curb stop to a point 1.5 Ft.

Stock: 2.0 ft. 3/4 copper tubing 1 3/4 curb stop

1 #1 Caldwell stop box 2 5/8 x 3/4 lead to cop adap.

comp.XS

8/14/87: Renewed from main to prop line.

Stock: 18.0 ft. 3/4" copper tubing 1-3/4" curb stop

used old Caldwell stop box 1-3/4x5/8 lead to cop adapt

xs 1-3/4x5/8 Fig. 413

=====

10/9/03 Excavated existing sewer line and replaced
16 ft. of 6" sewer; 6 ft. of 18" storm drain. It appears
when storm drain was put in existing sewer service was
relayed with pitch going wrong way.

[illegible]

CHARGE OUTS

[illegible]