

APPLICATION No.: 16414

LOCATION: 82-84 Park

OWNER: Dana C. Bessette

MEASURES: 5/8"

N from Arnold 205.0 ft.

W from E line Park 6.5 ft.

S. from N line House 10.3 ft.

Dec. 24, 1973 Repaired leak at the corporation tap.
2½ ft. - 3/4" Copper tubing 5/8" lead to copper
5/8" x 3/4" Fig. 413 adaptor XS

Jan. 2, 1974 Renewed from $\frac{1}{2}$ ft. outside curb stop to property line.

7 ft. - 3/4" Copper tubing 2 wipe joints
Caldwell Stop Box

12/9/86: Renewed from ½' outside curb stop to prop line.

Stock: 6ft. 6in. 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 2-3/4x5/8 lead to cop adapt. xs

7/16/87: Renewed from prop line to inside cellar.

(13.0 ft. ins prop line) Stock: 13 ft. 3/4" copper tubing 1-3/4 x 3/4 cop to cop cplg. comp..

8-2-2000 Zenone Const. renewed from main to curb stop. Stock:
22 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell
Stop Box, 1 - 5/8"x3/4" Fig.413. Zenone Const. to maintain cut.

TAP CLEARED 86493087

DATE _____

BEF.

AFT.

REMARKS

12/24/73

Reamed

8-2-2000	Tap	reamed
----------	-----	--------

8728.3087

[illegible]

CHARGE OUTS

[illegible]