

16466

TAP CLEARED

LOCATION:

OWNER:

MEASURES:

 $5/8''$

E from

Edison

24.0

N from S line

Glennom

9.0

W from E line

House

5.0

3/25/91: Renewed from $\frac{1}{2}$ ' outside curb stop to a point

2½ ft. Stock: 3ft. ¾" copper tubing

1- 3/4" curb stop 1-Caldwell stop box

2- $3/4 \times 5/8$ lead to cop adapt. xs. -----

10/27/04 Renewed from main to property line. Stock: 16 ft.

3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4"

lead-cop adapt. XS; 5/8" x 3/4" Fig. 413 Tap reamed

***Repaired 3 ft. section of sewer. Stock: 3 ft. 6" PVC: 2 clay-plas

fernco

12/8/16: JLC Construction water renewal, curb stop in

Inspector P.Reynolds

TO METER

[illegible]

CHARGE OUTS

[illegible]