


APPLICATION No.: 16491

TAP CLEARED 

LOCATION: 556 Middle Cor. Jenney

OWNER: Edw. D. Maynard

MEASURES:

1-1-1915

5/8"

S from

Middle

33.4 ft.

E from W line

Jenney

5.3 ft.

N from S line

House

1.1 ft.

1/20/93: Renewed from main to prop line Stock: 10ft 3/4" copper tubing 1-3/4" curb stop 1-Caldwell stop box 1-3/4x5/8 lead-cop adapt. 1-3/4x5/8 Fig 413

=====

9-17-08 - Dennis Trucking renewed service from property line into cellar - currently on by-pass system, under West End Rehab Contract #4 - Owner charged \$95 (\$70 inspection fee & \$25 for 3/4" meter couplings) Inspected by Manny Rose III

New measurements:

| | | |
|------------------------|-----------|------|
| S from S line | Middle St | 33.0 |
| E from W line | Jenney St | 4.0 |
| N from S line | House | 1.0 |
| S from N line | House | 25.0 |
| E from E line | House | 8.0 |
| Main to p roperty line | | 11.0 |
| Pipe inside property | | 5.0 |

9/17/08 - West End Water Main Rehab Contract # 4 - Perrina Const
Renewed service from main to a point 2 ft inside curb stop
9 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" curb stop
Inspected by Tim Ives, CDM

DATE

BEF.

AFT.

REMARKS

1-20-
93

9304-1201

1/20/93: tap reamed

[illegible]

CHARGE OUTS

[illegible]