

APPLICATION No.: 16512

TAP CLEARED

LOCATION: 854 Pleasant St. (Fire Station)

OWNER: N.B. Fire Dept.

MEASURES:

3" ~~copper~~

Darling gate -4"

E from

Pleasant

~~51.6 ft.~~ 47.3N ~~S~~ from S line

North

~~7.0 ft.~~ 18.5

E from W line

Fire Station

~~30.5 ft.~~ 34.0

S x S line

Bldg.

22.0

July 11, 14, 15, 1975 Federico renewed from the new 12" main into the cellar. He supplied all stock, labor, dug, backfilled, & will maintain trench.

1.5 ft. of 6" C.I.C.L. Ductile pipe class 2 2 4" C.I.C.L. class 250

20.3 ft. of 6" C.I.C.L. Ductile pipe class 22 1/8 bends

5 ft. of 3" copper tubing

4" x 3" cop. reducing

12" x 12" x 6" C.I.C.L. Class 250 tee, MJ

caulking connection

6" x 4" C.I.C.L. reducer, MJ class 250

4" lead joint

4" Smith private gate valve, MJ

4" 4" pipe straps, compl.

24 ft. of 5/8" threaded rod.

Buffalo gate box

MEASURES

12" x 12" x 6" Tee - E x E line Pleasant St. 45.6 ft.

S x N line North St. 23.5 ft.

6" x 4" Reducer - E x E line Pleasant St. 45.6 ft.

S x N line North St. 22.0 ft.

4" Gate Valve - E x E line Pleasant St. 45.6 ft.

S x N line North St. 20.5 ft.

[illegible]

CHARGE OUTS

[illegible]