

APPLICATION No.: 16574

## TAP CLEARED

LOCATION: 202-204 Mt. Pleasant

OWNER: Gertrude Saster

## MEASURES:

3/4"

S from

Coggeshall

65.6 ft.

W from E line

Mt. Pleasant 4.4

~~6.4~~ ft.

S from N line

House

11.4 ft.

Jan. 6, 1964 Renewed from 6" outside curb stop to 3 1/2  
ft. inside curb stop

4 ft. - 3/4" Copper tubing 3/4" cop to cop stop

2#wiping solder

AUG 18 1981

- - -

Renewed service from the main to 3" inside curbstop

12.0 ft. - 3/4" copper

1-1" x 3/4" Fig. 413 Tap reamed

1-3/4" curb stop 1-Caldwell stop box

Note: No saddle used on transite pipe.

DATE

BEF.

AFT.

REMARKS

AUG 18 1981

Reamed ✓

[illegible]





APPLICATION No.: 16574

TAP CLEARED

LOCATION: 202 - 204 Mt. Pleasant St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES: 3/4" Copper 05/01/1916

S from S line Coggeshall St 66.5  
W from E line Mt. Pleasant St 5.0  
S from N line House 12.0  
N from S line House 17.5  
W from W line House 18.5  
Main to Property line 14.0  
Pipe inside property 15.0

1/14/09 - Owner hired Dennis Trucking to renew service from  
curb stop into cellar. Inspected by Percy Reynolds - owner  
charged \$130 (\$30 shut-off, \$70 inspection & \$30 turn-on fees)  
New measures listed above  
-----

[illegible]

## CHARGE OUTS

[illegible]