

APPLICATION No.: 16590 5/8"

TAP CLEARED 8301 0133

LOCATION: 301 Court St.

OWNER: Alice M. Keehle

MEASURES: 5/8"

E from Wline

James (S)

12.9 ft.

S from N line

Court

6.5 ft.

E from W line

House

1.4 ft.

JAN 4 - 1983 - Renewed from 6" outside curbstop to 18" inside curb stop. 1.5 ft. - 3/4" copper; curb stop; stop box; 2- 5/8" x 3/4" lead-cop. adapt. XS;

June 28, 1984 - Renewed from 1/2 ft. outside curb stop to inside cellar.

16 Ft. - 3/4" copper tubing (7 Ft. inside)

1 - 3/4" curb stop; 1 stop box.

Dec. 17, 1996 Poor pressure - Meter dirty - Installed 3/4" blank - pressure good.

10/13/96 Renewed from main to a point 2 ft. N x main. All stock supplied & installed by Contractor. Stock: 2 ft. - 3/4" Copper tubing, 1 - 3/4" x 3/4" cop to cop cplg., Comp., 1 - 3/4" Corporation tap, 1 - 8 x 3/4 Service Saddle.

11/25/96 Renewed from main to a point 2 ft. All stock supplied & installed by Contractor. 2ft. - 3/4" Copper tubing, 1 - 3/4" x 3/4" Cop to Cop Cplg., Comp., 1 - 3/4" Corporation tap, 1 - 8 x 3/4" Service Saddle. M. Pavao to maintain cut.

- Botti Const. working for Nynex pulled tap from main.

DATE

BEF.

AFT.

REMARKS

8426-2074

965101173.

10/13/96

Tap reamed

11/11/96

Tap Reamed

[illegible]

CHARGE OUTS

[illegible]