

APPLICATION No.: 166 3/4"

TAP CLEARED

LOCATION: 192 Cottage St.

OWNER: Robert Andrade

MEASURES: 3/4"

E from Cottage 52.3 ft.

S from N line Court 6.1 ft.

W from E line Cor. house 8.1 ft.

Oct. 5, 1970 Renewed from 6" outside curbstop to the property line
 8 1/2' - 3/4" copper tubing 3/4" Hays curb stop
 2# wiping solder

Dec. 3, 1974 Renewed from the new 16" main in Court St.
 to the property line.

27 ft. - 3/4" Copper tubing 3/4" McDonald corp.
 3/4" McDonald curb stop 3/4" Ford lead to cop.
 Buffalo Stop Box adaptor XS (at prop. line)

Measures of new 3/4" Curb Stop:

E x E line Cottage St. 56.5 ft.

W x E line 188 Cottage St. 4.4 ft.

S x N line Court St. 5.4 ft.

S x S line 188 Cottage St. 10.3 ft.

4/25/77 - Coupling at curbstop leaking. Coupling tightened

8/31/77 Service discontinued - shut off at curb stop only.
 Replaced by New Service # 29592- 3/4"

✓ 73A710-2AT

[illegible]

CHARGE OUTS