

16619

APPLICATION No.:

TAP CLEARED

LOCATION: 4440 Acushnet Ave

OWNER:

31-313

MEASURES: May 25, 1916

S from Farnlin Ave 3.0'

W from E Acushnet Ave 6.5'

N from N line house 3.0'

N from S line Sassaquin Ave (west) 16.0'

1" COPPER

12-13-17: Lead service line replacement program
phase 1, TYPE CU, Diameter 1, Water Pressure N/A

Contractor: P. Gioioso & Sons

Distance from main to curb stop N/A

Distance curb stop to meter 48'

Distance from curb face to curb stop 1'

Depth of service 3.0'

Total length of new pipe installed 48'

Curb stop replaced: No Size 3/4"

Corporation replaced: NO Size 3/4"

Ball Valve furnished: YES size 1"

Remarks: used one 1" x 3/4" adpt. 8" from existing
curb stop

DATE

BEF.

AFT.

REMARKS

10-10-01

[illegible]

CHARGE OUTS

