

LOCATION: 172-4 Belleville Ave.

OWNER: Roland Deschenes

Jacks Auto Body

DATE

BEF.

AFT.

REMARKS

6/22/67

Reamed ✓

MEASURES: 5/8"

H lead

June 1, 1916

S from

Beetle

~~152.0 ft.~~

151.0 ft.

W from E line

Belleville Ave.

~~8.0 ft.~~

8.0 ft.

N from S line

Bldg.

~~2.6 ft.~~

3.3 ft.

Lead in trench Excavated for drain.

W x W line

House

9.1 ft.

June 22, 1967 Leak at tap.

1 ft. - 3/4" copper tubing; Tap reamed; 1 wipe joint;

1 - 5/8" reused tail piece.

Wipe joint is 1 ft. from main.

July 9, 1974 Renewed from 1/2 ft. outside curb stop to inside cellar.

15 ft. - 3/4" Copper tubing (6 ft. inside)

1 wipe joint 3/4" Curb Stop

Caldwell Stop Box

- - -

7/1/76: Due to the installation of the new 48" main this service was renewed from the main to a point 21 ft. from the main. Stock supplied

& installed by Zoppo; 1" Corporation Ford compression; 1" x 3/4" Reducer;

21 ft.-3/4" copper; 3/4" curb stop Ford compression; Measure of 1"

Corporation: S x S line Beetle St. 124.6 ft.; W x E line Belleville Ave. 29.0 ft.

11/5/92: Gioioso Const. crimped & cut by blasting & installing

30" forc main Cont. to maintain trench 1-3/4x3/4 cop-cop

cpplg comp 12ft W x curb stop BELLEVILLE AVE SEWER PROJ.

Insp. M Rose III -----

METER HISTORY

[illegible]

CHARGE OUTS