

APPLICATION No.: 16636

TAP CLEARED

LOCATION: 503 Hillman

OWNER: Helen Smith

MEASURES: 3/4"

E from

Jenny Lind

185.5 ft.

S from N line

Hillman

8.5 ft.

E from W line

House

11.3 ft.

Oct. 7, 1965 Renewed service from main to meter inside cellar
 45 ft. 3/4" copper tubing 3/4" cop. to cop. stop, fig. 415
 3/4" reused corporation coupling. 3/4" copper coupling, A-1525

5/20/91 called Radio Station - Mayor's office called
 Rusty Water took sample to Mayor's office Crystal Clear
 Mrs Bernado Councilor Alves called 2/21/91
 Congressman Studds office called 2/21/91
 Removed meter took water sample off street
 side of meter Crystal Clear Bento 2/21/91
 Problem Hot Water heater check valve does not work 3/21/91 ^{Bento}

6/23/08 - West End Water Main Rehab Contract # 4 - Perrina Const.
 Renewed water service from main to a point 5 ft
 5 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer
 Inspected by Tim Ives, CDM

DATE

BEF.

AFT.

REMARKS

10/7/63

reamed

[illegible]

CHARGE OUTS

[illegible]