

APPLICATION No.: 16661

TAP CLEARED

LOCATION: 101 Mt Vernon St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES: E X DeWolf St 27.0 ft  
S X N Line Mt. Vernon St 7.3 ft  
W X E Line House 3.6 ft

1" Copper Service

05/21/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 50

Distance from main to curb stop (ft) 19

Distance from curb stop to meter (ft) 22.7

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4.0

Total length of new pipe installed (ft) 22.7

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve replaced: yes size 1"

Remarks: 1-3/4 union installed 1 ft outside  
curb stop

[illegible]