81 COVE ST

APPLICATION No.: ~~16665~~

LOCATION: ~~85 Harbor~~

OWNER: Berkshire Hathaway

MEASURES:

2" Darling gate-Iron bx.		196.4 ft.
N from Cove		196.4 ft.
E from W line	Harbor	10.1 ft.
N from S line	No. 2 spinning mill	162.2 ft.

11-12-91 NOT READING - DIANE

April 2, 2003: 2" Tapp Gate valve broken in the iff position. Removed discs, repl bonnet, removed gate box. Installed a new 2" curb stop 2 ft W X exist gate valve. 2" curb stop; 2 ft-2" copper tubing; 2"x2" cop. to cop. cplg. comp.

TAP CLEARED ✓

DATE	BEF.	AFT.	REMARKS
4/3/03	800	AM	2003 131-0094

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
4-19-60		2"	Cadmet	1664279					

CHARGE OUTS