

APPLICATION No.: 16693

TAP CLEARED

LOCATION: 150-152 Deane St.

OWNER: A.P. Cloutier

MEASURES:

5/8"

S from	Deane	65.0
W from E line	Ashley Blvd.	9.1
S from S line	House	9.8

Mar. 14, 1957 Renewed from main to a point $2\frac{1}{2}$ ft. from main
 $2\frac{1}{2}$ ft. of $\frac{3}{4}$ " copper tubing $\frac{3}{4}$ " Cop. to I.F. cplg., fig 413
 1 lb. wiping solder

Feb. 5, 1969 Renewed from 6" outside curb stop to $4\frac{1}{2}$ inside curb
 stop 5 ft. - $\frac{3}{4}$ " copper tubing
 $\frac{3}{4}$ " Mueller curb stop 2-wipe joints.

July 11, 1969 Renewed from the curb stop to the property line.
 10 ft. - $\frac{3}{4}$ " copper tubing _ _ _ _ _ wipe joint

7/20/79: Repaired leak at a point $2\frac{1}{2}$ ft. from main. Cut
 out wipe joint. Replaced with 1- $\frac{5}{8}$ " x $\frac{3}{4}$ " lead-cop.
 adapt. XS;

DATE

BEF.

AFT.

REMARKS

3/4/57

reamed

June 26 1916

APPLICATION No.: 16693

LOCATION: 150-152 Deane St

OWNER:

31-313

MEASURES:

9-27-18

~~10/9/2018~~ emergency water service repair

3/4 copper tubing 5/8 corp adapter, 3/4 curb stop valve, cast iron curb stop box

Danny Perry

Manny Washburn

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]