

500 WEST ELM

APPLICATION No.: 16777

TAP CLEARED

LOCATION: ~~44 Jenney~~

OWNER: Leo E Braley

MEASURES: 5/8"

08/15/1916

S from

Elm-

51.9 ft.

W from E line

Jenney

4.1 ft.

S from S line

House

5.6 ft.

Nov. 30, 1981: Renewed 6" outside curbstop to the property line. 2.6 ft. - 3/4" copper; 3/4" curb stop; stop box; 2- 5/8" x 3/4" lead-cop. adapt. XS;

-----

5-29-92 = LOW PRESSURE, TROUBLE INSIDE BUILDING.  
BABE

-----

10/02/08 - West End Water Main Rehab Contract #4 -Perrina Const.  
Renewed service from main to a point 1 ft inside curb stop  
14.5 ft - 1" copper tubing; 1 - 1" Corp Tap; 1 - Curb stop;  
1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM

-----

11/5/2018: D

PO

RONNIE A. renewed service from curb stop to meter

[illegible]

## CHARGE OUTS

[illegible]



[Home](#)[All Work Orders](#) X[WO18\\_Work Orders - City](#) X

## Work Order #

18-012645

## Status

999 Complete

## Status Date

11/5/2018

## Status Time

02:49 PM

## Digsafe #

2018-3908639

## DigSafe Issued Date

10/1/2018

## Digsafe Expire Date

11/1/2018

Emergency

## Category \*

WD7

Water Service

## Problem

WDT420

Locate Request

## Main Task

WDT640

Repair

## Work Order

## Asset

## Address

500

## Street Name

ELM ST

## Foreman

10955

DANIEL PERRY

## Assigned To

10686

RONALD AGUIAR

## Department

WD

Water Distribution

## Priority

## Comment to Crew

Dug up main, it was already 3/4" copper f  
main to c/s.

Lead/meter comes out from rear of house  
driveway.

We were able to feed the cable and pull l  
C/s to meter only.

Material was soaked, had to put a steel p  
street cut.

## Comment from Crew

WATER RENEWAL - MAIN TO METER

## Start Date

10/4/2018

## End Date

10/4/2018

## Created By

a450cat