

2 Concord St.

APPLICATION No.: 16817

TAP CLEARED

LOCATION: ~~115 Query~~

OWNER: Oesty

MEASURES:

5/8"

E from Concord

26.3

N from N line Query

10.8

W from E line house

1.2

Oct. 31, 1994 Change of address per memo City Hall - Diane Martin

06/21/2013 City crew repaired curbstop leak. Renewed from main to property line. Stock: 28ft - 3/4" copper tubing; 1 - 3/4" curbstop; 1 - caldwell stop box; 1 - 5/8"X3/4" Fig 413. Tap Reamed. J.Medeiros

3/31/2022 JLC renewed curbstop to meter

Inspected PERCY R

Main to property line 31'

Pipe inside property 5'

DATE

BEF.

AFT.

REMARKS

6/21/13

2013-2511656
tap reamed

[illegible]