

APPLICATION No.: 16831

TAP CLEARED

LOCATION: 167 Durfee, Cor. Oakland

OWNER: Bermardino Costa

MEASURES: updated measures 10-8-19

Corner of building to box WXE line House 15'

House to box SXS Line House 13'

Main to property line SXS line 32'

Pipe inside property 14'

3/4"

W from	Oakland	72.8
S from N line	Durfee	6.4
E from Wline	House	12.5

Feb. 15, 1973 Renewed from 6" outside curb stop to a point 1 ft. inside curb stop.

1 1/2 ft. - 3/4" Copper tubing

2# wiping solder

3/4" Hays curb stop
Caldwell Stop Box

1/31/94: Renewed from main to a point 4ft in front of main
 Stock: 4ft 3/4" copper tubing 1-3/4x5/8 lead-ccp adapt.xxs
 1-3/4x3/4 Fig 413

=====

8-17-98 Renewed from 1 ft outside curb stop to a point 2 ft.
 front the curb stop. Stock: 3 ft - 3/4" Copper tubing

1 - 3/4" Curb Stop, 1 - Caldwell Stop Box, 1 - 3/4" x 3/4" lead to
 Cop. adapt. XS, 1 - 5/8" x 3/4" lead to cop. adapt. XXS

9-18-2000 Renewed from main to a point 15 ft. inside curb stop.
 27 ft. - 3/4" Copper tubing

1 - Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop. adapt. XXS,
 1 - 3/4" x 3/4" Fig. 413, 1 - 3/4" x 3/4" lead to curb stop.

over

DATE

BEF.

AFT.

REMARKS



1-31-94

T-9401968-05

1/31/94: tap reamed

8/17/98

981304345

9-18-2000 Tap reamed

METER HISTORY							CHARGE OUTS ✓		
DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
7-21-55		3/4	Hersey F.	1774659					
9-18-2000 Renewed from main to property line. Stock:									
27 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop									
1 - 3/4" Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop.									
adapt. XXS, 1 - 3/4" x 3/4" Fig. 413. Tilcon to maintain cut.									
10/10/2019 Renewed from curb stop to Meter									
JLC CONSTRUCTION CONTRACTOR Inspected by Percy R.									

Tap reamed 9-18-2000

CHARGE OUTS

Tap reamed 9-13-2000