

DUPLICATE
APPLICATION No.: 1684

85-41-0202
TAP CLEARED

LOCATION: 84 State ST.

OWNER: Sarah S. Dixon

MEASURES: 5/8"

S from Campbell st. 77.1 ft.
W from E line State St. 6.4 ft.
S from N line house 11.1 ft.

Aug. 7, 1979 Renewed from the main to
the property line.

26 ft. - 3/4" copper tubing

3/4" curb stop

1 Caldwell stop box

5/8" x 3/4" fig. 413

5/8" x 3/4" lead to cop adapt.

Cont. Franklin dug, backfilled & will maintain
trench.

10/7/85: Renewed from 1/2' outside curb stop to ins. cellar
(3ft. ins. prop line)

Stock: 9 ft. 3/4" copper tubing 1-3/4 curb stop

1 - Caldwell stop box

=====

=====

=====

DATE

BEF.

AFT.

REMARKS

GET

[illegible]

CHARGE OUTS

[illegible]

1684

TAP CLEARED

LOCATION: 84 State Street

OWNER: Sarah S. Dixon

MEASURES: 5/8"

S from ~~Campbell~~ 77.1 ft.

W from E line State 6.4 ft.

S from N line House 11.1 ft.

8/7/79: Franklin renewed service from the main to the prop. line.
26 ft. 3/4" copper; 3/4" curb stop; stop box; 5/8" x 3/4" Fig. 413;
5/8" x 3/4" lead-cop. adapt.

6/23/03 Electric Co. damaged 8" sewer service to house in sidewalk area while running new conduits to EMH. Excavated under electric conduit in sidewalk. Found broken sewer pipe 4 ft deep going towards street. Fixed 6 ft. section of 8" concrete sewer service. Stock: 6 ft. 8" PVC; 2 - 8" cement to PVC ferncoats

.....

[illegible]

CHARGE OUTS

[illegible]