

APPLICATION No.: 16924TAP CLEARED 9048-1171LOCATION: 29 Fair St.OWNER: Joao D. Pacheco *OWNER*

MEASURES: 5/8" H lead Jan.10,1917
E from Hall St. 188.3 ft.
S from N line Fair,St. 9.6 ft.
E from W line house 6.3 ft.

11/27/90: Renewed from 1/2' outside curb stop to ins.
cellar 13ft. ins. prop line. Stock: 23ft. 3/4"
copper tubing 1- 3/4" curb stop 1-Caldwell stop box
1- 3/4x5/8 lead to cop adapt. XXS =====

1" Copper Service

09/17/2018 Lead service line replacement program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 28.5

Distance curb stop to meter (ft) N/A

Distance from curb face to curb stop (ft) 2.0

Depth of service (ft) 6

Total length of new pipe installed (ft) 28.5

Curb stop replaced: yes, size 1"

Corporation replaced: yes, size 1"

Ball valve replaced: no

DATE

BEF.

AFT.

REMARKS

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
3-7-66		5/8	Rockwell Mg.	19378352					

CHARGE OUTS

