

APPLICATION No.: 1695

TAP CLEARED

LOCATION: 71 Bonney St.

OWNER: Joseph Pinto, Tr.

DATE

BEF.

AFT.

REMARKS

7/31/95

Reamed

MEASURES: 5/8" H lead Apr. 16, 1874

N from Washington St. 9.1 ft.

E from W line Bonney St. 6.0 ft.

Call 3/4/87 Leak inside of cellar wall

July 31, 1995 Cement lining Blocked tap

Renewed from main to a point 1 ft.

1 ft. - 3/4" copper tubing 1 - 5/8" x 3/4" lead to cop adapt XXS

1 - 5/8" x 3/4" fig. 413

3/4" Copper

N From N Line Washington St 9.1 ft

E From W Line Bonney St 6.0 ft

S From S Line House 7.0 ft

E From E Line House 31.0 ft

03/25/2013 R.J. Canessa renewed water service from
main to cellar; Inspected by P. Reynolds

METER HISTORY

CHARGE OUTS

[illegible]