

APPLICATION No.: 16975

TAP CLEARED 83-27-0231

LOCATION: 36 Jonathan

OWNER: Wm. Foster

MEASURES: 3/4"

S from	Union	228.7 ft.
W from E line	Jonathan	8.3 ft.
S from N line	house	5.5 ft.

July 7, 1983 Renewed leak from 6" outside curb stop to
4.5" inside curb stop.

2-3/4" x 5/8" XXS lead-cop. adapt.

1-3/4" curbstop 4.5 3/4" copper

1-stop box

7-14-99 DW White renewed from main to property line.
Stock: 31 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop
1 - Caldwell Stop box, 1 - 5/8" x 3/4" lead to cop.
adapt. XXS, 1 - 3/4" x 3/4" Fig. 413. DW White to
maintain cut.

7-31-99 Renewed from property line to inside cellar.
Stock: 15 ft. - 3/4" Copper tubing, 1 - 3/4" x 3/4" cop
to cop cplg., comp. Note: Service was turned on connected
into cellar cop to cop temporarily F. Bento.

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

7-14-99	Tap	reamed	
---------	-----	--------	--

[illegible]

CHARGE OUTS

[illegible]