

APPLICATION No.: 17TAP CLEARED ✓LOCATION: Purchase Cor. 53-55 Cor. MerrimacOWNER: P. KosciukowiczMEASURES: 3/4"

N from	Merrimac	43.8 ft.
E from W line	Purchase	7.0 ft.
S from N line	House	2.0 ft.

1" Copper Service

07/09/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) N/ADistance from curb stop to meter (ft) 13Distance from curbstop to curb face (ft) 5Depth of service (ft) 4Total length of new pipe installed 13


Curb stop replaced: NO, Corporation Replaced: No

Ball valve replaced: yes size 1"

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
2-6-62		3/4	Calmet	1736930					

CHARGE OUTS



53-55 Merrimac St APPLICATION No.: 17

LOCATION: Purchase

OWNER:

MEASURES:

3/4"

N from Merrimac

43.8

E from W line Purchase

~~7.0~~

3.0 ft.

S from N line house

~~2.0~~

8.5 ft.

Oct. 20, 1983 PURCHASE ST. WIDENING

Renewed from am in to the property line.

18 ft. - 3/4" copper tubing 3/4" curb stop

1 Caldwell stop box 5/8" x 3/4" fig. 413

5/8" x 3/4" lead to copper adapt XXS reamed tap

TAP CLEARED

DATE

BEF.

AFT.

REMARKS



[illegible]

CHARGE OUTS

METER HISTORY									
DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

This section is used to record charges against the meter.