

APPLICATION No.: 17		TAP CLEARED			
LOCATION:	OWNER:	DATE	BEF.	AFT.	REMARKS
69 Foster	Walter Thomas	2/30/03	030	am	2003-220-9138
MEASURES:					
5/8"					
S from	Maxfield				78.3
E from Wline	Foster				6.8
N from S line	House				8.2
Feb. 16, 1971 Renewed from main to property line					
14 ft. - 3/4" Copper tubing 3/4" Hays curb stop					
3/4" x 3/4 Hays Fig. 413 Buffalo Stop Box					
- - -					
Jan. 14, 1974 Renewed from property line to inside cellar.					
7 ft. - 3/4" Copper tubing 3/4" Copp. cplg.					
- - -					
5/30/03 Repaired sewer Stock: 9 ft - 6" PVC; 2 - 6" Fernco's plastic; NOTE: Sewer broken possibly when cable was installed					
Cable wires pulled duct; not in service; told by ComCast Grenon					

[illegible]

CHARGE OUTS

[illegible]