

APPLICATION No. 17109

TAP CLEARED

LOCATION: 135 Potter St.

OWNER:

MEASURES:	4"	Cast Iron Chap. gate
	W from W line Shawmut Ave.	280.6
	N from S line Potter St.	23.5
	W from E line bldg.	11.0

July 28, 1969 Renewed ser. #17109 at N.S. 135 Potter St., W x  
Shawmut Ave. - from the existing 4" Chapman Gate Valve to a point  
11 ft. inside the property line.  
35.5 ft. 4" C.I.C.L. Pipe 15 lbs. menerelead  
1 lb. Asbestos Yarning Rope 1 - 4" Pipe Strap-only

12/12/81 Repaired a cracked 4" service by installing a 4" Smith Blair #227 Clamp cplg. N x main pipe 14 ft. Main is 18 ft. N x S line Potter St.

Remeasured Ser.# 17109- 4" May 1, 1984  
W x W line Shawmut Ave. 290.4 ft.

[illegible]

## CHARGE OUTS