

APPLICATION No.: 17157

TAP CLEARED



LOCATION: 422 Hawes, S. E. Cor. Brockton

OWNER: Rosalie Braton

MEASURES:

3/4"

S from Brockton

20.2 ft.

W from E line Hawes

8.5 ft.

S from N line House

4.6 ft.

DATE

BEF.

AFT.

REMARKS

5/23/06

2006-200-7318

6/16/06

Tap Reamed

11/29/95 CONCERN OF LEAD PIPE. DAUGHTER WAS
TEST SLIGHT HIGH COUNT. TO HAVE WATER
TESTED - RECOMMENDED AQUATEL, INC

6/16/06 Renewed from main to property line. Stock:
28 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell
stop box; 5/8" x 3/4" lead-cop adapt. XXS; 3/4" x 3/4"
Fig. 413 Tap reamed

NOTE: Replaced 3 ft section of 6" asbestos with 2 -
asbestos-plastic fernco

[illegible]

CHARGE OUTS

[illegible]