

APPLICATION No.: 17179

TAP CLEARED

LOCATION: 215 Hersom St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

11/9/11 Ream

MEASURES: 01/01/1913

E X Conduit St 14.2 ft

S X N Line Hersom St 9.6 ft

E X W Line House 8.5 ft

1" Copper Service

04/29/2019 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Water pressure 85 Diameter 1in

Distance from main to curb stop (ft) 22

Distance curb stop to meter (ft) 25.5

Distance curb face to curb stop (ft) 2.5

Depth of service (ft) 4.3

Total length of new pipe installed (ft) 25.5

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball Valve furnished: yes size 1"

Remarks: 1-3/4" union installed 1 ft outside curb stop

[illegible]