

17309

TAP CLEARED

LOCATION: ~~23~~ Emery N.S., W. of Brock Ave.

OWNER: ~~John Henryhan~~ Southend (Schoolhouse)

MEASURES:

3" Darling gate I. box

W from Brock Ave. 452.6

N from S line Emma Emma 7.8

Service from Emma St.

20ft C.I. pipe including specials.

Feb. 17, 1998 While shutting down 3" gate for School Dept. plumber to change meter. - Valve broken closed. Removed inside installed. Valve on order - to be installed during school vaca.	disc - New 3" valve to be			
---	---------------------------	--	--	--

April 23, 1998 Replaced the 3" valve (broken closed see above report).  
Installed a 3" Mueller Gate Valve, Mech.

2 - 1 ft pcs of 3" Ductile pipe

2 .3" Smith Blair #441 Cast Cplgs.

Roadway box installed during 2/17/98 work.

[illegible]

## CHARGE OUTS

---

EUT