

APPLICATION No.: 17313

TAP CLEARED 846540

LOCATION: 177-179 Nash Rd.

OWNER: D.J. F. Mahoney

MEASURES: 5/8"

W from	Acushnet Ave.	128.3 ft.
S from N line	Nash Rd.	8.5 ft.
E from W line	House	1.5 ft.

August 18, 1977: Replaced Caldwell stop box

Nov. 13, 1984: Repaired 2 ft. outside tap. Stock: 1 5/8 x 3/4
Fig 413 2ft 3/4" copper tubing 1 3/4 x 5/8 lead
to copper adapt. XS -----

4/1/88 Renewed from 1' outside curb stop to prop line
6ft-3/4" copper tubing, 1-3/4" curb stop, 1-Caldwell stop box,
2-5/8x3/4 lead to cop adapt xs

9-17-98 Renewed from main to curb stop. Stock:
34 ft. 6 ins. - 3/4" Copper tubing, D.W. White to
maintain trench.

DATE

BEF.

AFT.

REMARKS

9-17-98 Tap reamed

[illegible]

CHARGE OUTS

[illegible]