

APPLICATION No.: 1733

TAP CLEARED

LOCATION: 89 Bonney St.

OWNER: Raymond S. Lima Et Ux

MEASURES: 3/4" H lead May 19, 1874

S from Washington St. 147.9 ft.

E from W line Bonney St. 5.8 ft.

N from N line house 3.5 ft.

April 10, 1973 Renewed from 6" outside curb stop to
inside cellar.

24 ft. - 3/4" Copper (16' ins.) by owner

3/4" Hays curb stop 3/4" x 3/4" lead to copper
Caldwell Stop Box - - - adaptor Ford

09.25.2018 - Lead Service Line Replacement Program

Contact: P. Gioioso and Sons

Type: CU, Diameter (in) 1, Water Pressure (PSI) 100

Distance from main to curb stop (ft) 12, Distance curb stop

to meter (ft) N/A, Distance from curb face to curb stop

(ft) 3, Depth of service (ft) 4.1, Total length of new pipe

installed (ft) 12

Curb stop replaced: Yes Size, 1", Corporation Replaced:

Yes Size 1" Ball Valve furnished No Size N/A

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

