

L 794 ✓

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

12/19/86: TAP REAMED

8651-2475  
MED  
call D. P. W 7:50

Dec. 9, 1980: Renewed from 6" outside curbstop to the property line.

8.0 ft.-3/4" copper

1-3/4" curb stop 1-Caldwell stop box

2-5/8" x 3/4" lead-cop. adapt. XS

12/19/86: Renewed from main to curb stop. Stock: 11.0ft. 3/4" copper tubing 1 - 3/4" curb stop used same Caldwell stop box 1 - 3/4 x 5/8 Fig. 413

7-24-2000 Silva Const. renewed from main to a point 5.5ft.  
Stock: 5.5ft.-3/4" Copper tubing, 1-3/4"x3/4" cop to cop  
cplg., comp. 1-3/4" Corporation tap. Silva Const. to  
maintain cut.

[illegible]

## This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. There is no text or other markings on the page.