

APPLICATION No.: 17353

TAP CLEARED: ✓

LOCATION: 52 Sawyer S.S., E. of Mitchell

OWNER: Fairhaven Mills

MEASURES: 3" C.I.
 3" darling gate I. box 2" meter.
 E from Mitchell 678.0 ft.
 N from S line Sawyer 8.5 ft.
 E from E line Mill #1 22.8 ft.
 181 ft. C.I. pipe & 4 ft. Galv. I. pipe including
 specials.

Location of cplg: S x 8" main 15 ft.; E x E line bldg. 23 ft.
 12/16/98 Repaired leak by installing a 3" Smith Blair #226 clamp cplg. 3.73-4.00 OD

Dec. 9 thru 18, 1997 Installed 2" copper service to supply Church in Fhvn Mill complex. Tied into
 existing 3" service at meter pit and installed service around concrete foundation.

All material & work done by Water Dept.

376 ft. - 2" Copper tubing 8 - 2" x 2" cop to cop cplg., comp.

Lawrence Plumb & htg. installed meter in pit & ball valve connection in pit - charged to
 Water Dept. See sketch attached for installation. Insp. F. Bento

Sept. 2, 1999 Waste Water digging inside prop pulled service. Replaced 4.5 ft. of 2" copper with a
 2" x 2" cop to cop cplg. @ point 13.6 ft. North from Church bldg.

At point 17.6 ft. north from church bldg. used existing cop cplg.
 4.5 ft. - 2" copper tubing 1 - 2" x 2" cop to cop cplgs.

Shutoff

[illegible]

CHARGE OUTS

[illegible]

NOTE: 2" COPPER SERV. TO SUPPLY WATER
FOR EXISTING CHURCH POR (CITY HALL)
EXISTING 3" SERVICE TIE-IN ON
SAWYER ST WAS USED TO TIE-IN
NEW 2" COPPER SERV. FROM METER-PIT ONLY

2" COPPER SERVICE WAS INSTALLED AROUND
CONCRETE FOUNDATION BURIED NEAR THE
OTHER SIDE OF MILL COMPLEX.

ALL MATERIAL AND WORK WAS DONE
BY NEW BEDFORD WATER DEPT.

IN THE METER-PIT SERVICE WAS CONNECTED
WITH 2"-441 TYPE ROLKWAHL 1-2" COP. TO COP
FOR TEMP. WATER.
PLUMBER NEED TO COMPLET JOBS FOR
METER CONNECTION.

F.B.

