

APPLICATION No.: 17382 5/8"

TAP CLEARED

LOCATION: 294 Collette St.

OWNER: Rodolphe J. Painchand

MEASURES: 5/8"

W from	Ashley Blvd.	336.0 ft.
N from S line	Collette	8.2 ft.
E from W line	House	9.3 ft.

9/26/78: Renewed 6" outside curb stop to inside callar wall. 17 ft.-3/4" copper (7 ft. ins); 3/4" curb stop; 5/8" x 3/4" lead-copper adapt. XXS; Caldwell stop box;

06.27.2018 Lead Service Line replacement program
Phase 1

Contractor P. Gioioso and Son

Type CU, diameter (in) 1, Water pressure 67

Distance curb stop to meter n/a

Distance from main to curb stop (ft) 10.0

Distance from curb face to curb stop (ft) 2.0

Depth of service (ft) 10.0

Total length of new pipe installed (ft) 10.0

Curb stop replaced: Yes, Size 1"

Corporation replace: Yes, Size 1"


Ball valve furnished: no

DATE

BEF.

AFT.

REMARKS



METER HISTORY

[illegible]

CHARGE OUTS